


UltraMax™

Digital Power Bus to 0-10V Interface



BEFORE YOU BEGIN

Read these instructions completely and carefully.

⚠ WARNING/AVERTISSEMENT

RISK OF ELECTRIC SHOCK

Turn power off before inspection, installation or removal.
Properly ground electrical enclosure.

RISK OF ELECTRIC SHOCK

Follow all NEC and local codes.
Use only UL approved wire for input/output connections.
Minimum size 14 AWG for continuous runs.

RISQUES DE DÉCHARGES ÉLECTRIQUES

Coupez l'alimentation avant d'inspecter, installer ou déplacer le luminaire.
Assurez-vous de correctement mettre à la terre le boîtier d'alimentation électrique.

RISQUES D'INCENDIE

Respectez tous les codes NEC et codes locaux.
N'utilisez que des fils approuvés par UL pour les entrées / sorties de connexion. Taille minimum 14 AWG.

Save These Instructions

Use only in the manner intended by the manufacturer. If you have any questions, contact the manufacturer.

Provided Components

- GEMOD/DB010
- Installation Guide

Tools and Parts Required

- Wire nuts
- Equipment necessary for luminaire disassembly
- Wire stripper/cutter

Installation Procedure and Troubleshooting

- Follow wiring diagram provided
- Secure interface within suitable enclosure
- Connect Interface Line (L) and Neutral (N) to input power
- Connect Relay Output to driver input Line and Connect Driver Neutral to input power Neutral
- Connect Digital + and Digital - to qualified sensing device
- If the device does not perform in the expected manner, do not attempt to repair, contact the manufacturer.

For Your Safety

Read and observe all WARNINGS shown throughout these instructions

- Installation to be performed by factory trained or qualified personnel
- This device is designed for field wiring in a suitable junction box in accordance with applicable codes
- Provide suitable enclosure for outdoor use
- Use this product only in the manner intended by the manufacturer. If there are any questions or concerns, contact the manufacturer
- This device complies with FCC Part 15 Subpart B Class B




imagination at work

Product Specifications

Characteristic	Parameter
Input power	120-277VAC 50/60HZ, Maximum 3A
Relay Contact	120-277VAC 50/60Hz, Maximum 3A
Housing	White
Size	7.08"lx1.38"wx0.93"h(180*35*23.5mm)
Wire Size	24-14 AWG, Solid or Tinned-Stranded Copper
Connectivity	Left : (N)Input, (L)Input, (L)Relay Output Right : 0-10V GND, 0-10V OUT, Dali+, Dali-
Output Power	1) 0-10 UL/NEC Class 2 protected 0-10V dimming , Maximum 32mA 2) 9.5V-22.5V UL/NEC Class 2 protected Digital-Power-Bus interface - with power provided by INTERFACE – nominal 22VDC.
Loading	1) 120-277V, 3A, General Use 2) 120-277V, 3A, Electronic Ballast
Function	Translate Digital-Power-Bus commands from compatible sensing Device: • On/Off – Relay Status • Dim Level – 0-10V Dimming Voltage Level
Warranty	5 years
Working Temperature	-20C to +50C
Certification	UL 60730-1/1310+FCC Part 15, Subpart B, Class B

Wiring Diagrams



Type 1.B action Pollution degree 2 Rated Impulse voltage 4000V

(N) Input	White	(-) 0-10V GND	Grey
(L) Input	Black	(+) 0-10V OUT	Purple
(L) Relay Output	Red	(+) Dali +	Purple w/ white stripe
		(-) Dali -	Yellow w/ white stripe

This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) This device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation. CAN ICES-005 (A) / NMB-005 (A)

This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures:

- Reorient or relocate the receiving antenna.
- Increase the separation between the equipment and receiver.
- Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.
- Consult the dealer or an experienced radio/TV technician for help.



www.gelighting.com

GE and the GE Monogram are trademarks of the General Electric Company. All other trademarks are the property of their respective owners. Information provided is subject to change without notice. All values are design or typical values when measured under laboratory conditions. GE Lighting and GE Lighting Solutions, LLC are businesses of the General Electric Company. © 2015 GE.

IRV 9/26/17